




Certificate Ref: **PDCERT2306140002**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				DBC125201RCD0152					
Appliance inlet type		C-Form		Rating (A)		125	1ph	3ph	x
Loop through outlet type		C-Form		Rating (A)		125	1ph	3ph	x
Does the loop through output have on board protection						YES		NO	x
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		60898		Breaking Capacity (KA)		16			
No of Poles		4		Fuse /Device rating or setting (A)		125			
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5		ma			
Visual Inspection Satisfactory				Yes	x	No	L1=Brown L2=Black L3=Gray		
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES	x	NO			
If No Give details									
Do all RCD test buttons operate correctly				YES	x	NO			
If No Give details									
Do all circuit indicators operate correctly				YES	x	NO	N/A		
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		Mohm	Satisfactory	x	Yes		No		
L2 - CPC		Mohm	Satisfactory	x	Yes		No		
L3 - CPC		Mohm	Satisfactory	x	Yes		No		
N-CPC		Mohm	Satisfactory	x	Yes		No		
Polarity throughout Satisfactory				Yes		No			
Test Instrument serial number				1009986102219630					
									
Inspected By		Pierre		Viraj					
Name		Pierre		Viraj					
Signature				Date		14/6/2023			

Certificate Ref: PDCERT2306140002

Schedule of Results

Distribution Board Serial Number or ID DBC125201RCD0152

Circuit Number	RCBO				RCD			Test results					Remarks (Continue on separate sheet if necessary)	
	Over current device				BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation		
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)										
Out1		A	40	10	61008	30	0	>99			✓	✓		
1	60898	C	16	6			0	>99	25.8	25	✓	✓		
2	60898	C	16	6			0	>99	26.3	23	✓	✓		
3	60898	C	16	6			0	>99	26.2	25	✓	✓		
Out2		A	40	10	61008	30	0	>99			✓	✓		
1	60898	C	16	6			0	>99	28.7	25	✓	✓		
2	60898	C	16	6			0	>99	28.6	25	✓	✓		
3	60898	C	16	6			0	>99	28.9	25	✓	✓		
Out3		A	40	10	61008	30	0	>99			✓	✓		
1	60898	C	16	6			0	>99	34.7	27	✓	✓		
2	60898	C	16	6			0	>99	35.1	25	✓	✓		
3	60898	C	16	6			0	>99	34.7	25	✓	✓		
Inspected By														
Name	Pierre				Viraj									
Signature				Date	14/6/2023									
Test Instrument details : Serial number					Megger MFT1741 1009986102219630									

