



Certificate Ref: **PDCERT2307040002**

Portable Power Distribution Unit Test and Inspection Certification										
Distribution Board Serial Number or ID					DBC163P04RCD0152					
Appliance inlet type			Not A/V		Rating (A)		1ph	3ph		
Loop through outlet type			Not A/V		Rating (A)		1ph	3ph		
Does the loop through output have on board protection							YES	NO		
Main Switch / Switch Fuse/ Circuit Breaker / RCD										
BS(EN)		Not A/V		Breaking Capacity (KA)						
No of Poles				Fuse /Device rating or setting (A)						
If Main Switch is RCD										
Rated residual operating current (ma)					Rated Time delay (ms)		N/A			
Operating time (ms)		X1	X5	ma						
Visual Inspection Satisfactory				Yes	<input checked="" type="checkbox"/>	No	L1=BROWN, L2=BLACK, L3=GREY			
If No Give details										
Functional Testing										
Do all MCBs maually operate correctly				YES	<input checked="" type="checkbox"/>	NO				
If No Give details										
Do all RCD test buttons operate correctly				YES	<input checked="" type="checkbox"/>	NO				
If No Give details										
Do all circuit indicators operate correctly				YES	<input checked="" type="checkbox"/>	NO	N/A			
If No Give details										
Insulation Resistance Tested at 250V due to sensitive equipment										
L1 - CPC		Mohm	Satisfactory	<input checked="" type="checkbox"/>	Yes		No			
L2 - CPC		Mohm	Satisfactory	<input checked="" type="checkbox"/>	Yes		No			
L3 - CPC		Mohm	Satisfactory	<input checked="" type="checkbox"/>	Yes		No			
N-CPC		Mohm	Satisfactory	<input checked="" type="checkbox"/>	Yes		No			
Polarity throughout Satisfactory				Yes	<input type="checkbox"/>	No				
Test Instrument serial number			1009986102219630							
Inspected By										
Name		Pierre								
Signature					Date		2023-04-07			



Certificate Ref: PDCERT2307040002

Schedule of Results													
Distribution Board Serial Number or ID						DBC163P04RCD0152							
Circuit Number	RCBO				RCD			Test results					Remarks (Continue on separate sheet if necessary)
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	
Out1		A	25	6	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	27.3	19	✓	✓	
Inspected By													
Name		Pierre											
Signature						Date		2023-04-07					
Test Instrument details : Serial number						Megger MFT1741 1009986102219630							

