


Certificate Ref: **PDCERT2307080011**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				MD125210RCBO0151					
Appliance inlet type		C-Form		Rating (A)		125	1ph	3ph	x
Loop through outlet type		C-Form		Rating (A)		125	1ph	3ph	x
Does the loop through output have on board protection						YES		NO	x
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		60898		Breaking Capacity (KA)		16			
No of Poles		4		Fuse /Device rating or setting (A)		125			
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5		ma			
Visual Inspection Satisfactory				Yes	x	No		L1=Brown L2=Black L3=Gray	
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES	x	NO			
If No Give details									
Do all RCD test buttons operate correctly				YES	x	NO			
If No Give details									
Do all circuit indicators operate correctly				YES	x	NO		N/A	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC	1.6	Mohm	Satisfactory	x	Yes		No		
L2 - CPC	2.6	Mohm	Satisfactory	x	Yes		No		
L3 - CPC	2.55	Mohm	Satisfactory	x	Yes		No		
N-CPC	1.9	Mohm	Satisfactory	x	Yes		No		
Polarity throughout Satisfactory				Yes		No			
Test Instrument serial number				1009986102219630					
Inspected By									
Name		Pierre							
Signature					Date		2023-08-07		





Certificate Ref: PDCERT2307080011

Schedule of Results	
Distribution Board Serial Number or ID	MD125210RCBO0151

Circuit Number	RCBO				Test results								Remarks (Continue on separate sheet if necessary)
	Over current device				RCD								
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	
Out1	61009	C	32	6	61009	30	0	>99	29.1	19	✓	✓	
Out2	61009	C	32	6	61009	30	0	>99	29	19	✓	✓	
Out3	61009	C	32	6	61009	30	0	>99	29	21	✓	✓	
Out4	61009	C	32	6	61009	30	0	>99	29.1	27	✓	✓	
Out5	61009	C	32	6	61009	30	0	>99	28.9	27	✓	✓	
Out6	61009	C	32	6	61009	30	0	>99	29.1	21	✓	✓	
Out7	61009	C	32	6	61009	30	0	>99	29	19	✓	✓	
Out8	61009	C	32	6	61009	30	0	>99	29	25	✓	✓	
Out9	61009	C	32	6	61009	30	0	>99	29	27	✓	✓	
Out10	61009	C	32	6	61009	30	0	>99	29	27	✓	✓	
Out11	61009	C	32	6	61009	30	0	>99	29.1	19	✓	✓	
Out12	61009	C	32	6	61009	30	0	>99	29	25	✓	✓	
Out13	61009	C	16	6	61009	30	0	>99	23.6	19	✓	✓	
Out14	61009	C	16	6	61009	30	0	>99	23.8	19	✓	✓	
Out15	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓	
Out16	61009	C	16	6	61009	30	0	>99	23.2	19	✓	✓	
Out17	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓	
Out18	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓	



Out19	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓
Out20	61009	C	16	6	61009	30	0	>99	23.8	19	✓	✓
Out21	61009	C	16	6	61009	30	0	>99	23.6	19	✓	✓
Out22	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓
Out23	61009	C	16	6	61009	30	0	>99	23.8	21	✓	✓
Out24	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓
Out25		A	40	10	61008	30	0	>99				
1	60898	C	32	6			0	>99	29.3	25	✓	✓
2	60898	C	32	6			0	>99	29.1	25	✓	✓
3	60898	C	32	6			0	>99	29.2	25	✓	✓
Out26		A	40	10	61008	30	0	>99			✓	✓
1	60898	C	32	6			0	>99	28.5	21	✓	✓
2	60898	C	32	6			0	>99	28.6	21	✓	✓
3	60898	C	32	6			0	>99	28.6	21	✓	✓
Out27		A	40	10	61008	30	0	>99			✓	✓
1	60898	C	32	6			0	>99	24.6	21	✓	✓
2	60898	C	32	6			0	>99	24.9	21	✓	✓
3	60898	C	32	6			0	>99	24.9	21	✓	✓
Out28		A	40	10	61008	30	0	>99			✓	✓
1	60898	C	32	6			0	>99	25.2	21	✓	✓
2	60898	C	32	6			0	>99	25.1	19	✓	✓
3	60898	C	32	6			0	>99	25	19	✓	✓
Out29		A	63	10	61008	30	0	>99			✓	✓
1	60898	C	63	6			0	>99	24.8	21	✓	✓
2	60898	C	63	6			0	>99	25.1	21	✓	✓
3	60898	C	63	6			0	>99	25	21	✓	✓
<div style="display: flex; justify-content: space-between; align-items: center;"> <div style="width: 40%;"> <p>Inspected By</p> <p>Name Pierre viraj</p> <p>Signature  Date 2023-08-07</p> </div> <div style="width: 20%; text-align: center;">  </div> <div style="width: 35%; text-align: right;"> <p>Test Instrument details : Serial number Megger MFT1741 1009986102219630</p> </div> </div>												

