

Certificate Ref: **PDCERT2309090010**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				DBM63595MCCB0152					
Appliance inlet type		C-Form		Rating (A)		63	1ph	3ph	<input checked="" type="checkbox"/>
Loop through outlet type				Rating (A)			1ph	3ph	
Does the loop through output have on board protection						YES		NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		60898		Breaking Capacity (KA)		6			
No of Poles		3		Fuse /Device rating or setting (A)		63			
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5				ma	
Visual Inspection Satisfactory									
				Yes	<input checked="" type="checkbox"/>	No		L1=BROWN, L2=BLACK, L3=GRAY	
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES	<input checked="" type="checkbox"/>	NO			
If No Give details									
Do all RCD test buttons operate correctly				YES	<input checked="" type="checkbox"/>	NO			
If No Give details									
Do all circuit indicators operate correctly				YES	<input checked="" type="checkbox"/>	NO		N/A	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		Mohm	Satisfactory	<input checked="" type="checkbox"/>	Yes			No	
L2 - CPC		Mohm	Satisfactory	<input checked="" type="checkbox"/>	Yes			No	
L3 - CPC		Mohm	Satisfactory	<input checked="" type="checkbox"/>	Yes			No	
N-CPC		Mohm	Satisfactory	<input checked="" type="checkbox"/>	Yes			No	
Polarity throughout Satisfactory				Yes		No			
Test Instrument serial number				1009986102219630					
Inspected By									
Name		Pierre		Date		2023-09-09			
Signature									

