


Certificate Ref: **PDCERT2308310002**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				DBM32083RCD0152					
Appliance inlet type		C-Form	Rating (A)	32	1ph		3ph	x	
Loop through outlet type		C-Form	Rating (A)	32	1ph		3ph	x	
Does the loop through output have on board protection				YES			NO	x	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)	60898		Breaking Capacity (KA)		6				
No of Poles	3		Fuse /Device rating or setting (A)		32				
If Main Switch is RCD									
Rated residual operating current (ma)			Rated Time delay (ms)			N/A			
Operating time (ms)		X1	X5		ma				
Visual Inspection Satisfactory				Yes	x	No	L1=BROWN, L2=BLACK, L3=GRAY		
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES	x	NO			
If No Give details									
Do all RCD test buttons operate correctly				YES	x	NO			
If No Give details									
Do all circuit indicators operate correctly				YES	x	NO		N/A	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		Mohm	Satisfactory	x	Yes		No		
L2 - CPC		Mohm	Satisfactory	x	Yes		No		
L3 - CPC		Mohm	Satisfactory	x	Yes		No		
N-CPC		Mohm	Satisfactory	x	Yes		No		
Polarity throughout Satisfactory				Yes		No			
Test Instrument serial number				1009986102219630					
Inspected By									
Name		Pierre							
Signature					Date		31/8/2023		



Certificate Ref: PDCERT2308310002

Schedule of Results	
Distribution Board Serial Number or ID	S/N DBM32083RCD0152

Circuit Number	RCBO				Test results								Remarks (Continue on separate sheet if necessary)
	Over current device				RCD			Test results					
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	
Out1		A	40	10	61008	30	0	>99			v	v	
1	60898	C	32	6			0	>99	28.7	23	v	v	
2	60898	C	32	6			0	>99	28.8	25	v	v	
3	60898	C	32	6			0	>99	28.9	25	v	v	
4	60898	C	32	6			0	>99	28.8	25	v	v	
5	60898	C	32	6			0	>99	28.8	25	v	v	
6	60898	C	32	6			0	>99	29	25	v	v	
1	60898	C	32	6			0	>99	28.8	25	v	v	
2	60898	C	32	6			0	>99	28.6	25	v	v	
3	60898	C	32	6			0	>99	28.8	25	v	v	
4	60898	C	32	6			0	>99	28.7	25	v	v	
5	60898	C	32	6			0	>99	28.7	25	v	v	
6	60898	C	32	6			0	>99	28.9	25	v	v	
1	60898	C	32	6			0	>99	28.6	25	v	v	
2	60898	C	32	6			0	>99	28.7	25	v	v	
3	60898	C	32	6			0	>99	28.8	25	v	v	
4	60898	C	32	6			0	>99	28.9	23	v	v	
5	60898	C	32	6			0	>99	28.4	21	v	v	
6	60898	C	32	6			0	>99	28.8	21	v	v	



Inspected By	
Name	Pierre
Signature	<i>[Signature]</i>
Date	31/8/2023



Test Instrument details : Serial number Megger MFT1741 1009986102219630