


Certificate Ref: PDCERT2309230010

Schedule of Results

Distribution Board Serial Number or ID **DBM32095RCBO0161**

Circuit Number	RCBO				RCD			Test results					Remarks (Continue on separate sheet if necessary)
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	
OUT													
1	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓	
2	61009	C	16	6	61009	30	0	>99	23.6	21	✓	✓	
3	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓	
4	61009	C	16	6	61009	30	0	>99	23.7	19	✓	✓	
5	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓	
6	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓	
7	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓	
8	61009	C	16	6	61009	30	0	>99	23.2	19	✓	✓	
9	61009	C	16	6	61009	30	0	>99	23.5	27	✓	✓	
Inspected By													
Name	Pierre		Nawazish										
Signature			Date	23/9/2023									
Test Instrument details : Serial number					Megger MFT1741 1009986102219630								

