


Certificate Ref: **PDCERT2309090003**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				DB325P06C163P10153					
Appliance inlet type			Rating (A)		32	1ph		3ph	X
Loop through outlet type			Rating (A)			1ph		3ph	
Does the loop through output have on board protection					YES		NO		
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)				Breaking Capacity (KA)					
No of Poles				Fuse /Device rating or setting (A)					
If Main Switch is RCD									
Rated residual operating current (ma)					Rated Time delay (ms)		N/A		
Operating time (ms)		X1		X5				ma	
Visual Inspection Satisfactory				Yes	x	No			
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES	x	NO			
If No Give details									
Do all RCD test buttons operate correctly				YES	x	NO			
If No Give details									
Do all circuit indicators operate correctly				YES	x	NO		N/A	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		Mohm	Satisfactory	x	Yes			No	
L2 - CPC		Mohm	Satisfactory	x	Yes			No	
L3 - CPC		Mohm	Satisfactory	x	Yes			No	
N-CPC		Mohm	Satisfactory	x	Yes			No	
Polarity throughout Satisfactory				Yes		No			
Test Instrument serial number				1009986102219630					
Inspected By									
Name		Pierre		Date		2023-09-09			
Signature									



Certificate Ref: PDCERT2309090003

**Schedule of Results**

Distribution Board Serial Number or ID **DB325P06C163P10153**

Circuit Number	RCBO				RCD			Test results					Remarks (Continue on separate sheet if necessary)
	Over current device				BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)									
<b>Out1</b>		<b>A</b>	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	28.7	21	✓	✓	
2	60898	C	16	6			0	>99	28.4	23	✓	✓	
3	60898	C	16	6			0	>99	28.4	21	✓	✓	
4	60898	C	16	6			0	>99	28.3	25	✓	✓	
5	60898	C	16	6			0	>99	28.3	21	✓	✓	
6	60898	C	16	6			0	>99	28.5	21	✓	✓	



**Inspected By**

Name **Pierre**

Signature

Date **2023-09-09**

Test Instrument details : Serial number

Megger MFT1741 1009986102219630