





Certificate Ref: **PDCERT2309110001**

Portable Power Distribution Unit Test and Inspection Certification										
Distribution Board Serial Number or ID				DBM63184RCD0153						
Appliance inlet type		C-FORM		Rating (A)		63		1ph	3ph	x
Loop through outlet type				Rating (A)				1ph	3ph	
Does the loop through output have on board protection						YES		NO		
Main Switch / Switch Fuse/ Circuit Breaker / RCD										
BS(EN)		60898		Breaking Capacity (KA)		6				
No of Poles		3		Fuse /Device rating or setting (A)		63				
If Main Switch is RCD										
Rated residual operating current (ma)				Rated Time delay (ms)		N/A				
Operating time (ms)		X1		X5				ma		
Visual Inspection Satisfactory										
Yes				x		No				L1=BROWN, L2=BLACK, L3=GREY
If No Give details										
Functional Testing										
Do all MCBs maually operate correctly				YES		x		NO		
If No Give details										
Do all RCD test buttons operate correctly				YES		x		NO		
If No Give details										
Do all circuit indicators operate correctly				YES		x		NO		N/A
If No Give details										
Insulation Resistance Tested at 250V due to sensitive equipment										
L1 - CPC		Mohm	Satisfactory	x	Yes		No			
L2 - CPC		Mohm	Satisfactory	x	Yes		No			
L3 - CPC		Mohm	Satisfactory	x	Yes		No			
N-CPC		Mohm	Satisfactory	x	Yes		No			
Polarity throughout Satisfactory				Yes		No				
Test Instrument serial number				1009986102219630						
Inspected By										
Name		Pierre		Zeshan						
Signature				Date		2023-11-09				



Certificate Ref: PDCERT2309110001

Schedule of Results													
Distribution Board Serial Number or ID						DBM63184RCD0153							
Circuit Number	RCBO				RCD			Test results					Remarks (Continue on separate sheet if necessary)
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	
<b>Out1</b>		<b>A</b>	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	29.1	25	✓	✓	
2	60898	C	16	6			0	>99	28.8	25	✓	✓	
3	60898	C	16	6			0	>99	28.7	21	✓	✓	
4	60898	C	16	6			0	>99	28.6	25	✓	✓	
5	60898	C	16	6			0	>99	28.8	21	✓	✓	
6	60898	C	16	6			0	>99	28.7	21	✓	✓	
<b>Out2</b>		<b>A</b>	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	28.7	19	✓	✓	
2	60898	C	16	6			0	>99	28.7	19	✓	✓	
3	60898	C	16	6			0	>99	28.6	19	✓	✓	
4	60898	C	16	6			0	>99	28.5	19	✓	✓	
5	60898	C	16	6			0	>99	28.7	19	✓	✓	
6	60898	C	16	6			0	>99	28.6	19	✓	✓	
<b>Out3</b>		<b>A</b>	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	26.1	25	✓	✓	
2	60898	C	32	6			0	>99	26.4	25	✓	✓	
3	60898	C	32	6			0	>99	26.2	23	✓	✓	
<b>Inspected By</b>													
Name	Pierre				Zeshan								
Signature					Date	2023-11-09							
Test Instrument details : Serial number						Megger MFT1741 1009986102219630							