

Certificate Ref: **PDCERT2309080004**

Portable Power Distribution Unit Test and Inspection Certification

Distribution Board Serial Number or ID		DBR325P0220154					
Appliance inlet type	C-Form	Rating (A)	32	1ph		3ph	x
Loop through outlet type	C-Form	Rating (A)	32	1ph		3ph	x
Does the loop through output have on board protection				YES		NO	x

Main Switch / Switch Fuse/ Circuit Breaker / RCD			
BS(EN)		Breaking Capacity (KA)	
No of Poles		Fuse /Device rating or setting (A)	
If Main Switch is RCD			
Rated residual operating current (ma)		Rated Time delay (ms)	N/A
Operating time (ms)	X1	X5	ma


Visual Inspection Satisfactory	Yes	x	No		L1=Brown L2=Black L3=Gray
If No Give details					

Functional Testing	
Do all MCBs maually operate correctly	YES <input type="checkbox"/> NO <input type="checkbox"/>
If No Give details	Not available
Do all RCD test buttons operate correctly	YES <input type="checkbox"/> NO <input type="checkbox"/>
If No Give details	Not available
Do all circuit indicators operate correctly	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/> N/A <input type="checkbox"/>
If No Give details	

Insulation Resistance Tested at 250V due to sensitive equipment						
L1 - CPC		Mohm	Satisfactory	x	Yes	No
L2 - CPC		Mohm	Satisfactory	x	Yes	No
L3 - CPC		Mohm	Satisfactory	x	Yes	No
N-CPC		Mohm	Satisfactory	x	Yes	No

Polarity throughout Satisfactory	Yes	No
----------------------------------	-----	----

Test Instrument serial number	1009986102219630
-------------------------------	------------------

Inspected By	
Name	Pierre
Signature	
Date	2023-08-09

