

Certificate Ref: **PDCERT2309080015**

## Portable Power Distribution Unit Test and Inspection Certification

Distribution Board Serial Number or ID		SB165P06C163P0153					
Appliance inlet type	C-Form	Rating (A)	16	1ph	3ph	<b>X</b>	
Loop through outlet type	C-Form	Rating (A)	16	1ph	3ph	<b>x</b>	
Does the loop through output have on board protection			YES		NO	<b>x</b>	

Main Switch / Switch Fuse/ Circuit Breaker / RCD					
BS(EN)		Breaking Capacity (KA)			
No of Poles		Fuse /Device rating or setting (A)			
If Main Switch is RCD					
Rated residual operating current (ma)		Rated Time delay (ms)		N/A	
Operating time (ms)	X1	X5	ma		



Visual Inspection Satisfactory		Yes	<b>x</b>	No	L1=Brown
If No Give details					

Functional Testing					
Do all MCBs maually operate correctly		YES		NO	
If No Give details		Not available			
Do all RCD test buttons operate correctly		YES		NO	
If No Give details		Not available			
Do all circuit indicators operate correctly		YES	<b>X</b>	NO	N/A
If No Give details					

Insulation Resistance Tested at 250V due to sensitive equipment						
L1 - CPC		Mohm	Satisfactory	<b>x</b>	Yes	No
L2 - CPC		Mohm	Satisfactory	<b>x</b>	Yes	No
L3 - CPC		Mohm	Satisfactory	<b>x</b>	Yes	No
N-CPC		Mohm	Satisfactory	<b>x</b>	Yes	No

Polarity throughout Satisfactory	Yes		No	
----------------------------------	-----	--	----	--

Test Instrument serial number	1009986102219630				
-------------------------------	------------------	--	--	--	--

Inspected By					
Name	Pierre				
Signature			Date	2023-08-09	